



386 N Midler Ave
Syracuse, NY 13206

Telephone: 315-466-4147

SHOOTER ATTACK ASSEMBLY TESTING WITH AMBICO DOORS

IN ACCORDANCE WITH FTD-SA STANDARDS

TEST SUBJECT: AMBICO ATTACK RESISTANT STEEL DOOR
GLAZING: ARMoured ONE 7/16" LAMINATED GLASS WITH 23 MIL
SHOOTER ATTACK FILM

TEST DATE(S): 1/19/2022

LOCATION: FILTI TEST LABS

**SCOPE OF WORK: SHOOTER ATTACK AND
IMPACT ASSEMBLY TESTING ON AMBICO DOORS**



386 N Midler Ave
Syracuse, NY 13206

Telephone: 315-466-4147

SECTION 4

SUMMARY

TESTING WAS COMPLETED ON FOLLOWING:

FRAME: AMBICO

GLAZING: ARMoured ONE 7/16" LAMINATED GLASS AND 23 MIL SHOOTER ATTACK FILM

THE RESULTS SHOW SPECIMEN #1 PASS CLASS 6 AFTER REPEATED HITS DIRECTLY ON THE GLASS. GLASS FAILURE WAS SEEN AFTER THE SECOND HIT OF CLASS 7 AT 200 FT/LBS.

THE RESULTS SHOW SPECIMEN #2 PASS CLASS 5 AFTER REPEATED HITS DIRECTLY ON THE LOCK AND LATCH. DOOR FAILURE WAS SEEN AFTER THE SECOND HIT OF CLASS 6 AT 175 FT/LBS.