

LISTING INFORMATION OF

Habersham Metal Windstorm Door and Frame Assembly with Frame Mounted Lock

SPEC ID: 38277

Habersham Metal Products Company, Inc. 264 Stapleton Road Cornelia, GA 30531 United States

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

LISTING INFORMATION

Habersham Metal Windstorm Door and Frame Assembly with Frame Mounted Lock

ICC 500 -2008 PRODUCT ASSEMBLY & RATINGS

Product and Model No.

Assembly Type	Permitted Size	Design Pressure	Impact Rating
Metal Windstorm Door and Frame Assembly with Frame Mounted Lock	Max: Single Outswing Size – 4'-0" wide x 7'-0" high Max: Clear View Glass Size for Glazing– 31-3/4" wide x 33-7/8" high	+/- 51.4 psf	9 lb 2x4 @ 64 mph
Configuration	Door: Habersham 12 Gau Frame: Habersham 12 Ga Latching Hardware: Sout Electro-Mechanical Deadl Hinges: (4) Northwest Spe hinge with security stud Door Closer: Not Evaluate Door Bottom: Not Evaluate Protection Plate: Not Evaluate Vision Kit: 3/4" Thick Glob Glazing Weather Seals: 1/8" glazi Electric Power Transfer: Door Position Switch: Not Threshold: Not Evaluated Mag Lock: Not Evaluated	auge Frame thern Steel 10120AMD-2 atch Jamb Mounted Locks ecialty Hardware 4 ½" x 4 ed aluated ted bal Security Glazing Secu ng tape required on each Not Evaluated of Evaluated	set ½" x 3/16" institutional r-Tem+Ploy SP 2115

Attribute	Value
Criteria	ASTM E1886 (2005)
Criteria	ICC-500 (2008)
Criteria	ASTM E330 (2014)
CSI Code	08 11 00 Metal Doors and Frames
Intertek Services	Certification
Listed or Inspected	LISTED
Listing Section	WINDSTORM - SWING DOOR ASSEMBLIES
Spec ID	38277
Test Original Issue Date	2016-07-26